

FORAY LABORATORIES PTY. LTD.

2/27 Normanby Road
Clayton North, 3168
www.cetec-foray.com.au

Telephone: 03-9544-9111
Fax: 03-9544-9122
Email: info@cetec-foray.com.au

LABORATORY REPORT: 0605-10 **Client: RLA Polymers Pty Ltd**

1 SAMPLE IDENTIFICATION AND DESCRIPTION

Adhesive product was analysed as received on May 12th, 2006.

Table 1: Sample Identification and Description

Sample Identification	Description
58068	Intertac Adhesive

Samples to be analysed VOC content as per Green Star – Office Design Technical Manual of the Green Building Council. This involved testing according to South Coast Air Quality Management Division (SCAQMD) Rule 1168. This references SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials.

2 RESULTS

	58068
Density (g/mL)	1.020
Total Volatiles (%)	60
Water Content (%)	59
Exempt Compounds (%)	None Detected
VOC Content Material (g/L)	10